

DEP
TITLE 15, CHAPTER 20
Direct except from page 23

(s) **Service Pipe Repairs.**

A new service pipe must be installed where more than one-half (1/2) of an existing service pipe is in need of a repair or when any repairs are required and the existing service pipe is lead, galvanized steel or galvanized iron. All repairs must conform with the standards described in 20-03 of these Rules.